

TỔNG CỤC TIÊU CHUẨN ĐO LƯỜNG CHẤT LƯỢNG

TRUNG TÂM CHỨNG NHẬN PHÙ HỢP (QUACERT)



ENSURE YOUR SUCCESS

GIẤY CHỨNG NHẬN

Sản phẩm: Ống luồn dây điện uốn được bằng nhựa PVC

với nhãn hiệu thương mại



được sản xuất tại

CÔNG TY CỔ PHẦN SAM PHÚ

Trụ sở công ty : Số 199, tổ 8, khu B, ấp 6, xã An Phước, huyện Long Thành, tỉnh Đồng Nai, Việt Nam

Xưởng sản xuất: Cụm công nghiệp Long Phước, xã Long Phước, huyện Long Thành, tỉnh Đồng Nai, Việt Nam

có các chỉ tiêu phù hợp với yêu cầu của tiêu chuẩn

IEC 61386-1:2008 & BS EN 61386-22:2004+A11:2010

- Khả năng chịu nén: nhẹ (2);
- Khả năng chịu va đập: nhẹ (2);
- Khả năng chịu nhiệt độ cao: +60 °C (1);
- Khả năng chịu uốn: mềm (4);
- Đặc tính điện: có đặc tính cách điện và liên tục về điện (3);
- Khả năng chống cháy lan: không cháy lan (1).

Phương thức chứng nhận: Phương thức 5 (theo Thông tư số 28/2012/TT-BKHCN ngày 12/12/2012 và Thông tư số 02/2017/TT-BKHCN ngày 31/3/2017 của bộ khoa học và công nghệ)

Số Giấy chứng nhận: SP 2259/3.23.14

Hiệu lực Giấy chứng nhận: từ ngày 08/6/2023 đến ngày 07/6/2026

GIÁM ĐỐC



Trần Quốc Dũng

QUACERT - 8 Hoàng Quốc Việt, P. Nghĩa Đô, Q. Cầu Giấy, Hà Nội, Việt Nam



ENSURE YOUR SUCCESS

CERTIFICATE

This is to certify that the Products as: **Pliable conduit PVC for cable management**

with Trade Mark



made by

SAM PHU CORPORATION

Head office: No. 199, Group 8, Area B, Hamlet 6, An Phuoc Commune, Long Thanh District, Dong Nai Province, Vietnam

Factory: Long Phuoc Industrial Zone, Long Phuoc Commune, Long Thanh District, Dong Nai Province, Vietnam

have been found to conform with those characteristics of the standard

IEC 61386-1:2008 & BS EN 61386-22:2004+A11:2010

- Resistance to compression: light (2);
- Resistance to impact: light (2);
- Resistance to upper temperature: +60 °C (1);
- Resistance to bending: flexible (4);
- Electrical characteristics: with electrical continuity & insulating characteristics (3);
- Resistance to flame propagation: non-flame propagating (1).

Certification System: SYSTEM 5 (Circular No. 28/2012/TT-BKHCN dated 12 Dec 2012 and Circular No. 02/2017/TT-BKHCN dated 31 March 2017 of MOST)

Certificate Number: SP 2259/3.23.14

The validity of this Certificate: from 08 June 2023 to 07 June 2026

Director



Trần Quốc Dũng